

Synchronized Reserve Market Design Options

EPFSTF

June 8, 2018

Catherine Tyler



Monitoring Analytics

Reserve Locations

PJM

- RTO Zone
- Single predefined subzone
- Subzones published quarterly and posted in real time

IMM

- RTO Zone
- Any subzone area for which a transmission constraint prevents the use of RTO reserves, for the loss of a generator.
- Subzones published quarterly and posted in real time.

Synchronized Reserve Eligibility

PJM

- electrically located in PJM
- synchronized to the grid
- 10 min. response
- not emergency capacity
- sustain for 30 minutes
- available to provide reserves (ex: not testing)

IMM

- electrically located in PJM (not pseudo tied)
- synchronized to the grid
- 10 min. response
- not emergency capacity
- sustain for 30 minutes
- available to provide reserves (ex: not testing)

Tier 1 and Tier 2

PJM

- **Consolidate Tier 1 and 2**
- **Pay all cleared reserves the market price**
- **Impose the same obligation and penalties on all cleared reserves**

IMM

- **Consolidate Tier 1 and 2**
- **Pay all cleared reserves the market price**
- **Impose the same obligation and penalties on all cleared reserves**

Adjustments to Available Reserve MW Estimates

PJM

- **Deselection by unit class**
- **Continue to adjust offer MW by the Degree of Generator Performance (DGP) in the last 30 minutes**
- **Eliminate Tier 1 bias**

IMM

- **Deselection only by defined unit class, no unit specific deselection**
- **Eliminate DGP adjustments**
- **Eliminate Tier 1 bias**

Synchronized Reserve Max Output

PJM

- **Less than or equal to Eco. Max**
- **Used only with prior PJM approval for physical operating reason**
- **Must exceed 0 MW**

IMM

- **Less than or equal to Eco. Max**
- **Used only with prior PJM approval for physical operating reason**
- **Must exceed 0 MW**

Synchronized Reserve Ramp Rate

PJM

- **Remove reserve ramp rates**
- **Use energy ramp rates**

IMM

- **Remove reserve ramp rates**
- **Use energy ramp rates**
- **Allow for hourly ramp rates with real time updates**
- **Create tariff requirement that Market Sellers must submit based on physical operating capability only**

Synchronized Reserve Availability

PJM

- **Online, PJM scheduled capacity resources**
- **Resources without capacity commitment default to availability, may opt out**

IMM

- **All resources available for energy are available for reserves.**

Synchronized Reserve Offer Price

PJM

- Offer price up to an established margin, plus condensing costs
- Margin currently \$7.50/MW
- Remove VOM from offer

IMM

- Offer price up to an established margin, plus condensing costs
- Revise margin to reflect market behavior
- Remove VOM from offer

Synchronized Reserve Nonperformance Penalty

PJM

- **SRMCP x shortfall MW**
- **For all hours of SR over the past 19 days or since the resource last failed to respond to SR event**

IMM

- **SRMCP x shortfall MW**
- **For all hours of SR over the past 19 days or since the resource last failed to respond to SR event**
- **Adjust shortfall MW so that penalty equals past SR revenues**

Monitoring Analytics, LLC

2621 Van Buren Avenue

Suite 160

Eagleville, PA

19403

(610) 271-8050

MA@monitoringanalytics.com

www.MonitoringAnalytics.com

